



SNAP-N-STRUT LTD
MS S WITKOWSKI
4115 HWY 51 N
JANESVILLE WI 53545

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500

RE: Project Number(s) - 01RT6872

Your most recent Certification is shown below. You may also view this information, or a portion of this information (depending on the product category), on UL's Online Certifications Directory at www.ul.com/database. Please review the text and contact the Conformity Assessment Services staff member who handled your project if revisions are required. For instructions on placing an order for this information in a 3 x 5-inch format, you may refer to the enclosed order form for UL Card Service.

DWMU
Conduit and Cable Hardware

September 25, 2001

SNAP-N-STRUT LTD
4115 HWY 51 N, JANESVILLE WI 53545

E218244

Hangers.

Hangers, Cat. Nos. 25-29, 30-34, 35-38, 48-54, 56-63, 66-76, 79-93, 101-115.

LOOK FOR LISTING MARK ON PRODUCT

196185001

A not-for-profit organization
dedicated to public safety and
committed to quality service



DWMU.E218244 Conduit and Cable Hardware

[Page Bottom](#)

Conduit and Cable Hardware

[See General Information for Conduit and Cable Hardware](#)

SNAP-N-STRUT LTD

E218244

4115 HWY 51 N

JANESVILLE, WI 53545 USA

Hangers, Cat. Nos. 21-24, 25-29, 30-34, 35-38, 40-44, 48-54, 56-63, 66-76, 79-93, 101-115, may be followed by a P or E.

[Last Updated](#) on 2002-11-11

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".



MS. SHELLEY SKILDUM
SNAP-N-STRUT LTD
2820 PRAIRIE AVE
BELOIT WI 53511

Date: 2013/10/03
Subscriber: 196185001
PartySite: 25453
File No: E218244
Project No: 13RS16416
PD No: 13M42042
Type: R
PO Number:

Subject: Procedure And/Or Report Material

The following material resulting from the investigation under the above numbers is enclosed.

Issue

<u>Date</u>	<u>Vol</u>	<u>Sec</u>	<u>Pages</u>	<u>Revised Date</u>
	1		Revised Authorization Page(s)	2013/10/03

SR# 21082 - ADDRESS CHANGE FOR SNAP-N-STRUT LTD

Please file revised pages and illustrations in place of material of like identity. New material should be filed in its proper numerical order.

NOTE: Follow-Up Service Procedure revisions DO NOT include Cover Pages, Test Records and Conclusion Pages. Report revisions DO NOT include Authorization Pages, Indices, Section General Pages and Appendixes.

Please review this material and report any inaccuracies to UL's Customer Service Professionals. Contact information for all of UL's global offices can be found at <http://www.ul.com/global/eng/pages/corporate/contactus>.

If you'd like to receive updated materials FASTER, UL offers electronic access and/or delivery of this material. For more details, contact UL's Customer Service Professionals as shown above.

This material is provided on behalf of UL LLC(UL) or any authorized licensee of UL.

NBK File



**Underwriters
Laboratories Inc.**

**Research Triangle
Park Division**

12 Laboratory Drive
P.O. Box 13995
Research Triangle Park, NC 27709-3995 USA
www.ul.com
tel: 1 919 549 1400
fax: 1 919 547 6000
Customer service: 1 877 854 3577

4/5/2004

Ms. S Witkowski
Snap-N-Strut Ltd
4115 Hwy 51 N
Janesville WI 53545

Our Reference: File E218244
Your Reference: S WITKOWSKI
Subject: Preliminary Evaluation

Dear Ms. Witkowski:

We have completed our preliminary evaluation of your product and have the following comments.

For the record we are investigating the above subject product, using requirements from our standard for Hardware for the Support of Conduit, Tubing, and Cable, UL 2239. Please note that all paragraphs referenced below are from this Standard.

The constructions submitted are identical to the constructions currently covered in File E218244. This investigation is for the construction type 30-34 and smaller. These samples are being submitted to our Northbrook office for testing to the requirements for Smoke and Heat Release as described in Section 6.9.

MARKINGS

Provided that the tested constructions comply with the applicable requirements of the Standard, the following marking may be applied on the smallest unit carton or installation instructions:

"Suitable for use in Air Handling Spaces in accordance with Section 300.22 (C) and (D) of the National Electrical Code, and Rules 12-010 (3), (4), and (5), and 12-020 of the Canadian Electrical Code, Part 1" or an equivalent wording.

Please advise how you intend to provide these markings.

If you have any questions, please do not hesitate to contact us.

Sincerely,

Reviewed by:

Bryan L. Tatum
Senior Project Engineer
Department: 3015ERTP
Tel: 919-549-1939
Fax: 919-316-5624
E-mail: bryan.l.tatum@us.ul.com

Vincent L Quiett
Staff Engineer
Department: 3015ERTP
E-mail: vincent.l.quiett@us.ul.com

An independent organization working for a safer world with integrity, precision and knowledge

